

Emission Test Certificate

Wednesday November 16th, 2005

Supplier: Interface Australia Pty Ltd (4 Henry Street, Picton NSW 2511)

Sample Description: GlasBacRE

Date Tested: November 2005

Test Method: Carpet & Rug Institute Green Label Plus test program incorporating ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Carpet & Rug Institute Green Label Plus Specification	GlasBac The results for "GlasBacRE" can be considered representative of the whole range of solution dyed nylon modular carpet with GlasBac, GlasBacRE and System Six backing
Total Volatile Organic Compound emission rate < 0.5 mg/m ² /hr (14 days)	Total Volatile Organic Compound emission rate < 0.01 mg/m ² /hr (14 days)
"Chemicals of Concern": Formaldehyde Acetaldehyde Benzene Caprolactam 2-Ethylhexanoic Acid 1-Methyl-2-Pyrrolidinone Naphthalene Nonanal Octanal 4-Phenylcyclohexene Styrene Toluene Vinyl Acetate	Emission Rate: 0.001 mg/m ² /hr 0.006 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr <0.007 mg/m ² /hr <0.003 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr <0.002 mg/m ² /hr 0.002 mg/m ² /hr <0.002 mg/m ² /hr
The "chemicals of concern" were present in the product to a very low extent and would pose insignificant health effect to building occupants when used in the typical manner.	



Dr. Vyt Gampys
 PhD, BSc(Hons) AIMM, ARACT, ISIAQ, ACA, AIRAH, FMA
 Managing Director and Principal Consultant