



VOC Content Test Certificate

Wednesday August 18th, 2010

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137)

Sample Description: Intertac Modified Adhesive

Date Tested: August 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Intertac Modified Adhesive
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	11 grams per Litre as VOC content per material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Intertac Modified Adhesive
Indoor Carpet Adhesive 50 grams per Litre as VOC content material	11 grams per Litre as VOC content per material

Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F1008-05